



اَبُو سَيِّدِي تَيْكُو لُو كِي مَارَا
UNIVERSITI
TEKNOLOGI
MARA

THE DOCTORAL RESEARCH ABSTRACTS

Volume: 6, Issue 6 November 2014

**SIXTH
ISSUE**

INSTITUTE of GRADUATE STUDIES

Leading You To Greater Heights, Degree by Degree

IPSis Biannual Publication

Name :

Nur Fadilah Ab Aziz

Title :

**New Techniques Incorporating
Computational Intelligence Based
For Voltage Stability Evaluation
And Improvement In Power System**

Supervisor :

**Associate Prof. Dr. Zuhaina Hj. Zakaria
(MS)**

**Prof. Dr. Hjh. Titik Khawa Abdul
Rahman (CS)**

* (MS) = Main Supervisor (CS) = Co Supervisor

Recently, there are still many cases of voltage collapse incidents occur all around the world. This is due to the reason that most power systems today are being operated very close to their stability limits because of the exponentially growing demands, the desires to obtain maximum economic benefits and environmental constraints. Therefore, this thesis presents novel techniques for voltage stability evaluation and enhancement in power system. Firstly, a new bus voltage stability index named as Voltage Stability Condition Indicator (VSCI) was developed. The competency of VSCI was corroborated in three tasks; weak bus identification, automatic line outage contingency ranking and weak area identification. In addition, a new method to detect weak areas in a system termed as Weak Area Clustering Margin (WACM) was also developed. In the first part of study, all methods were tested on IEEE 30-bus and IEEE 118-bus test system. Secondly, a new voltage stability prediction technique utilising state of the art machine learning, Support Vector Machine (SVM) was developed. At this stage, two popular SVM selection parameter methods, trial and error and cross validation were investigated and compared. The developed technique used VSCI as the voltage stability indicator to be predicted. The performance of SVM was also compared with the performance of Artificial Neural Network (ANN). To enhance the SVM performance, an outstanding

hybrid Artificial Immune Least square Support Vector Machine (AILSVM) that integrates SVM with Artificial Immune System (AIS) was introduced in voltage stability prediction. For comparison, another new hybrid algorithm incorporating ANN and AIS called as Artificial Immune Neural Network (AINN) for voltage stability prediction was also developed. It was found that AILSVM has outclassed AINN significantly in terms of prediction accuracy and computation time. Thirdly, new techniques for load margin improvement were developed. Initially, a superior performance of AIS named as Fast Artificial Immune System (FAIS) to estimate the maximum load margin of a system was developed. FAIS offers a better performance of AIS since several available approaches for cloning, mutation and selection have been explored and compared. The combination of these approaches that delivered the best performance in terms of accuracy and time was utilised in FAIS. Later on, another novel technique that incorporates FAIS and AILSVM known as Fast Artificial Immune Support Vector Machine (FAISVM) for maximum load margin improvement via

RPP optimisation was developed. The integration of FAIS and AILSVM has resulted to a very fast and accurate prediction of maximum loading point (MLP) as the objective function for Reactive Power Planning (RPP) optimisation. The proposed technique employed the predetermined support vectors from AILSVM. VSCI was used as the indicator for the MLP of load buses. Another new hybrid algorithm that used Evolutionary Programming (EP) termed as Evolutionary Support Vector Machine (ESVM) was also developed for comparative study. The results showed that FAISVM has outperformed ESVM significantly in terms of load margin improvement, prediction accuracy and computation time. For the second and third part of the study, the developed techniques were tested on IEEE 30-bus test systems. In conclusion, this thesis has developed a new voltage stability index, VSCI and novel techniques known as AILSVM and FAISVM for voltage stability prediction and maximum load margin improvement that utilised biological optimisation method.