

**ANALYSIS AND RECOMMENDATIONS ON ENERGY
CONSERVATION ON THE EXISTING BUILDING**

**This project is presented in fulfillment for the award of the
Bachelor of Electrical Engineering (Honours)
MARA UNIVERSITY OF TECHNOLOGY**



MOHD SYAIFUL NIZAM BIN ISMAIL
Faculty of Electrical Engineering
MARA UNIVERSITY OF TECHNOLOGY
40450 Shah Alam
Selangor

ACKNOWLEDGEMENT

I would like to express my deepest gratitude to my project supervisor, Prof. Madya Ir. Zulkefli Yaacob for he valuable guidance, comments and ideas towards the success of this project.

My gratitude also goes to my family who had given me moral support, assistance and prayed for my success. Also thank to my entire colleague for suggestion and contribution toward the success of this project.

I am also indebted to the various help and discussions offered by Mr. Ir. Harizan, Mr. Che Izam and his teams of UiTM Maintenance Office.

Finally, I would like to express my great thankfulness to various people that involved on this project, especially Mr. Ismail Musirin and Mr Fadzli bin Abdullah

ABSTRACT

This project presents a study on energy conservation in existing building. This project describes how to analyse and make recommendations to reduce both energy consumption and operating costs. For the purpose of this project offers a field-tested approach to identify, analyse and recommend action on the wide range opportunities and options available to reduce energy usage in most existing building. In this case study, Kolej Delima, UiTM Shah Alam is being selected.

TABLE OF CONTENTS

CHAPTER	DESCRIPTION	PAGE
1	INTRODUCTION	
	1.0 Introduction	1
	1.1 Types of Energy Audit	2
	1.1.1 Walk Through Audit	3
	1.1.2 Utility Cost Analysis	3
	1.1.3 Standard Energy Audit	4
	1.1.4 Detailed Energy Audit	4
2	LITERATURE REVIEW	
	2.0 Introduction to HVAC System	6
	2.1 Thermal Comfort, Air Quality and Airflow	6
	2.1.1 Thermal Comfort	6
	2.1.2 Air Velocity and Airflow	8
	2.1.3 Indoor Air Quality	9
	2.2 Maintenance	9
	2.3 Demand Management	10
	2.3.1 Operating Schedule	10
	2.3.2 Night Set-Back	12
	2.3.3 Warm-up and Cool Down	13
	2.4 Introduction to Lighting System	15
	2.5 Energy Efficient Lighting System	17
	2.5.1 High Efficiency Fluorescent Lamps	19
	2.5.2 Compact Fluorescent Lamps	21
	2.5.3 Compact Halogen Lamps	21
	2.5.4 Electronic Ballasts	21
	2.6 Lighting Controls	23
	2.6.1 Occupancy Sensors	23

CHAPTER	DESCRIPTION	PAGE
	2.6.2 Lighting Dimming System	25
3	METHODOLOGY	
	3.0 Introduction	26
	3.1 Selecting and Establishing the Energy Efficiency Management Team	26
	3.2 Building Description and Function	26
	3.2.1 Electrical Supply	29
	3.2.2 Lighting	29
	3.2.3 General Equipment	29
	3.2.4 Air-Conditioning System	30
	3.2.5 Building Automation System	30
	3.2.6 Fresh Water Supply	30
	3.3 Historical Consumption	30
	3.4 Load Apportioning	31
	3.5 Calculation on Lighting Load	33
	3.6 Calculation on Air-Conditioning Load	34
4	RESULTS AND DISCUSSION	
	4.0 Introduction	35
	4.1 Replacement of Standard Ballast (12W Loss) to Low-Loss Ballast (6W Loss)	35
	4.2 Replacement of Monophosphour to Triphosphour Lamp	35
	4.3 Replacement of existing non-reflector luminaires with mirror-reflector fitting complete with triphosphour lamp and low-loss ballast	36