

UNIVERSITI TEKNOLOGI MARA

**ENERGY EFFICIENCY OF AN
UNBALANCED DISTRIBUTION
SYSTEM BASED ON THE
CONSERVATIVE VOLTAGE
REDUCTION WITH OPTIMAL
PLACEMENT AND SIZING OF
CAPACITOR USING ANT COLONY
OPTIMIZATION TECHNIQUE**

MOHD AINOR BIN YAHYA

Thesis submitted in fulfillment
of the requirements for the degree of
Master of Science

Faculty of Electrical Engineering

April 2018

ABSTRACT

Energy efficiency can be achieved through reducing the loss of the power by using an adequate amount of power in an electrical distribution system. In this thesis, the energy efficiency is analysed based on an electrical distribution system along with the implementation of the Conservative Voltage Reduction (CVR), and the Optimal Capacitor Placement and Sizing (OCPS). In order to determine optimal location and sizing of the capacitors, Ant Colony Optimization (ACO) is implemented. The capacitors will ameliorate the energy efficiency through energy consumption and power loss minimization. Prior the ACO is implemented to solve OCPS, specific number of busbars is allocated. The Power-Loss-Index (PLI) is performed to achieve the pre-selection of busbar. Three variables will represent the objectives and fitness of the proposed optimization technique, which are, the total cost of power losses, energy consumption and capacitor installation. The parameters that are considered as the proposed optimization technique constraints are; the voltage magnitude limit, Total Harmonic Distortion (*THD*) limit, power factor limit and capacitor size limit. Conservative Voltage Reduction (CVR) is used to gain further enhancement of the energy efficiency. This is achieved through changing the transformer tap setting in order to lower and then retain the voltage magnitude at a specific level whilst ensuring the stability of the electrical distribution system. In this study, MATLAB[®] is used as a platform to implement the proposed methods. These techniques will firstly transfer the information, execute the three-phase unbalanced load flow solution and retrieve. Then it will collect the results or data from the three-phase unbalanced electrical distribution systems which are modeled in the SIMULINK[®] toolbox. The evaluation and the effectiveness of the conducted methods, in order to improve the energy efficiency, are verified through several case studies. The findings are collected from two test systems, IEEE 13-bus unbalanced electrical distribution system and the pragmatic electrical distribution system model of Sultan Salahuddin Abdul Aziz Shah (SSAAS) building in Shah Alam, Selangor. Finally, our proposed methodology has shown ability to reduce the cost utility bills of SSAAS building. Particularly, our methodology managed to reduce the cost of maximum demand in utility bills.

ACKNOWLEDGEMENT

In the name of Allah. The Most Beneficent and The Most Merciful

My foremost praise to the Almighty Allah for all His blessings for giving me the strength and patience throughout the duration of this Master research. First of all, I would like to give my deepest appreciation to my main supervisor, Associate Professor Dr. Muhammad Murtadha bin Othman, for his unfailing support, ideas, word of encouragement, assistance, support, guidance and insightful discussion and meetings he shared with me throughout this research and during the preparation of this Master thesis.

I would also like to extend my sincerest thanks to my co-supervisors, Professor Dr. Ismail bin Musirin for his advice and encouragement throughout my studies. I also wish to express my appreciation to Research Management Institute (RMI), Universiti Teknologi MARA (UiTM) and Ministry of Energy, Green Technology and Water (KeTTHA) for the financial assistance for me to conduct this research.

My warmest thanks and appreciation goes to my lovely wife, Zuriyana Binti Awang, my beloved father Yahya Bin Ibrahim, my beloved mother, Aspah Binti Bulat and all my family members as well as my in laws whose love and ceaseless support that have brought me to this level, their prayers that have helped me to succeed and provide me with strength throughout the years of my studies.

Finally, my special thanks go to Ir. Mat Nasir Bin Kari and Ir. Zilaila Binti Zakaria from Malaysian Public Work Department (JKR), Mr. Shaharani Jaafar from Selangor State Government Office (Sultan Salahuddin Abdul Aziz Shah (SSAAS) building) for their invaluable sharing of knowledge to make this research project a success. Likewise, special thanks also go to Mr. Muhd Azri Bin Abd Razak and all my colleagues in the Power and Energy with Artificial intelligence Research Laboratory (PEAiRL), Faculty of Electrical Engineering, UiTM Shah Alam, for their comments, ideas, opinions and assistance in making my research a success.

TABLE OF CONTENTS

	Page
CONFIRMATION BY PANEL OF EXAMINERS	ii
AUTHOR'S DECLARATION	iii
ABSTRACT	iv
ACKNOWLEDGEMENT	v
TABLE OF CONTENTS	vi
LIST OF TABLES	x
LIST OF FIGURES	xii
LIST OF NOMENCLATURES	xvii
CHAPTER ONE: INTRODUCTION	1
1.1 Background And Significance Of Research	1
1.2 Problem Statement	3
1.3 Research Objectives	4
1.4 Scope Of Work	4
1.5 Significant Of Study	7
1.6 Organization Of Thesis	8
CHAPTER TWO: LITERATURE REVIEW	10
2.1 Introduction	10
2.2 Optimal Capacitor Placement And Sizing (OCPS) In Unbalanced Electrical Distribution System	11
2.2.1 Previous Solution for OCPS	11
2.3 Conservartive Voltage Reduction (CVR)	14
2.3.1 Implications in Implementing CVR	15
2.3.2 Approaches based CVR Implementation	16
2.4 Summary	17
CHAPTER THREE: METHODOLOGY	19

CHAPTER ONE

INTRODUCTION

1.1 BACKGROUND AND SIGNIFICANCE OF RESEARCH

The definition of 'energy efficiency' is the usage of energy-frugal, prudent and wise. The main aims of using energy efficiency are to reduce the expenses, cost of living and avoid wastage thus will establish a beneficial service to the nature. The reduction of energy consumption, and the cost power generation will leads to reduce the use of fossil fuels and as well as the impact of harmful gas emissions to the environment. However, due to the instability of the fossil fuel in the world market, the companies based power generation intends to increase the utilities bill and this will hinder the initiative which intensity on the agenda of energy efficiency.

With the concern on the environmental effects, the Malaysian Prime Minister, Dato' Sri Najib Tun Razak had announced a pledge during the 2009 United Nations summit on climate change in Copenhagen. The pledge stated that Malaysia has a commitment to a 40% reduction in terms of greenhouse gas emission intensity of Gross Domestic Product (GDP) by the year 2020 comparing to another information published in 2005 [1]. Apart from that, the 10th Malaysian Plan (2011-2015) under Energy Policies has emphasized on the energy efficiency as one of the most important agenda [2]. This corroborated by several number of organized programmes, such as the SAVE programed (rebate for selected energy efficient electrical appliances), formulation of Energy Efficiency Master Plan, Energy Labeling and Minimum Energy Performance Standards (MEPS), and Green Building Index (GBI).

There are several issues or problems which incite to an inefficient consumption of energy in the distribution systems, such as the harmonic. Harmonics in power systems may lead to the increase of heating in the equipment and conductors. The installation of shunt capacitors, without considering the existence of harmonic source in the distribution system, may cause an increasing in the harmonic distortion levels due to the resonance between capacitors and inductive element in the system [3]. The production of the harmonic in a distribution system is hard to be controlled. It is